



**BUREAU
VERITAS**

Certificate

Manufacturer / applicant: **SolaX Power Network Technology (Zhe jiang) Co., Ltd.**
No. 288 Shizhu Road, Tonglu Economic Development Zone,
Dongxing District 311500, Tonglu City, Zhejiang Province,
People's Republic of China

Product type: **Grid-tied and stand-alone battery storage inverter**

Model: **X1-AC-3.0, X1-AC-3.6, X1-AC-4.6, X1-AC-5.0**

Ratings:	X1-AC-3.0	X1-AC-3.6	X1-AC-4.6	X1-AC-5.0
Input DC voltage range [V]:	70-400			
Input DC current [A]:	35	35	35	35
Output AC voltage [V]:	220/230/240 50/60Hz			230/240 50/60Hz
Output AC current [A]:	13,6	16,8	21	21,7
Output power at 230Vac [VA]:	3000	3680	4600	4999

The certificate refers to the stated model(s) which passed the tests according to the applicable standard(s):

IEC 62477-1:2012; IEC 62477-1 A1:2016

Safety requirements for power electronic converter systems and equipment – Part 1: General

Report number: **SXP-18MY0493FTSP**

Certificate number: **U19-0324**

Date of issue: **2019-05-28**

Certification body

Holger Schaffer
Holger Schaffer



**Deutsche
Akkreditierungsstelle
D-ZE-12024-01-00**

Certification body of Bureau Veritas Consumer Products Services Germany GmbH
Accredited according to DIN EN ISO / IEC 17065